Technical Data

Effective May 2017

Recessed and floor box receptacles

Project Name:	Prepared By:
Project Number:	Date:
Catalog Number:	Туре:





TR775





Description

2-Pole, 3-Wire Grounding NEMA 5-15R



5-15R

Design features

- Tamper Resistant shutters provide compliance with 2017 NEC[®] Article 406.12 that states that all receptacles installed in dwelling units must be tamper resistant
- Floor box assembly includes tamper resistant receptacle on recessed mounting strap, 18 cu. in steel back box, solid brass cover, gasket and threaded brass closure cap with watertight neoprene rubber "O" ring
- Double-wipe ground contacts ensure long term ground retention ٠
- Tri-combo screws accept Slotted-, Phillips-, and Robertson-head tools for installation flexibility

Table 1. Recessed receptacles

	Description		Rating	
Catalog No.			V/AC	
🗆 TR775W	Tamper resistant NEMA 5-15R single receptacle, white with clock hanger, side wire	15	125	
□ TR780W	Tamper resistant NEMA 5-15R duplex receptacle, side wire and pushwire	15	125	

Table 2. Floor box receptacles

		Rating	
Catalog No.	Description	A	V/AC
🗆 TR5797	Tamper resistant NEMA 5-15R single receptacle, brass floor box assembly, side wire	15	125
□ TR5249B	Tamper resistant NEMA 5-15R duplex receptacle, brass floor box assembly, side wire	15	125

Compliances, specifications and availability are subject to change without notice.



TR780

15A, 125V/AC